



**Highland City Administration Department**  
**5400 West Civic Center Drive ~ Suite 1**  
**Highland, UT 84003**  
**Phone 801- 756-5751 | Fax 801-756-6903**

Mitchell Hollow Trail Questions & Answers  
December 22, 2025

**Question:** What does it mean that some of the items (#8, #13, #18, etc) in the M&P say “NOT USED” next to them?  
Could you please clarify?

**Response:** *"Items that state "NOT USED" in the M&P are items that had been included in the original design but have been removed while the city negotiates with homeowners. They may be added in the future as a change order to the selected contractor but should not be included in the bid. The city will be issuing a second addendum in early January to clarify some items on the bid schedule."*

**Question:** Please verify What the safety railing post size, type of materials and color is powder coated. Also, what are the size plates and anchors to mount the post.

**Response:** *See Special Provision 02826S Safety Rail for design requirements, member sizing and connections. Note under Article 1.5, the contractor, or contractor's fabricator is required to submit for review Working Drawings, shop drawing, calculations, etc. for the design of the railing. Requirements for materials including minimum member sizing are found in Article 2.1. All members are required to be steel and galvanized after fabrication per Article 2.2.*

*Safety Railing is to be mounted to Precast Concrete Boardwalk. In Special Provision 03320S Concrete Boardwalk, special coordination is required between the contractor, the railing manufacturer, the concrete boardwalk manufacturer and the helical design/provider. Note anchor spacing for the railing posts will need to be coordinated with the precast boardwalk manufacturer to ensure fit.*